



कार्यालय,
अधिशाली अभियन्ता,
खण्ड कार्यालय, उ०प्र० जल निगम(ग्रामीण),
महाराजगंज

पत्रांक:
सेवा में,

472/V-35 / 60

दिनांक: 17/04/2025

प्रधानाचार्य,
नवजीवन मिशन स्कूल,
सोनौली रोड आनन्दनगर,
महाराजगंज।


विषय:- पानी की शुद्धता की जाँच रिपोर्ट के सन्दर्भ में।

महोदय,

उपरोक्त विषयक आपके द्वारा दिनांक 12.04.2025 को 1 नग जल नमूनों का गुणवत्ता परीक्षण हेतु उपलब्ध कराये गये हैं। प्राप्त 1 नग जल नमूनों का परीक्षण इस खण्ड के विभागीय प्रयोगशाला में किया गया, जिसका परीक्षण रिपोर्ट पत्र के साथ संलग्नकर प्रेषित है।

संलग्नक- जल परीक्षण रिपोर्ट।


भवदीय


अधिशाली अभियन्ता

पुं०सं० एवं दिनांक तदैव:-

प्रतिलिपि: निम्नलिखित को सूचनार्थ प्रेषित।

1. सहायक अभियन्ता/जू०इं० (प्रयोगशाला)।


अधिशाली अभियन्ता


**PROFORMA FOR SAFE DRINKING WATER AND SANITARY
CONDITION CERTIFICATE**

No. 772/V-35/60

Date 16.04.2025

It is certified that an inspection team headed by EXECUTIVE ENGINEER from DIVISION OFFICE U.P JAL NIGAM (RURAL) DISTRICT-MAHARAJGANJ inspected the Nav Jeevan Mission School, Sonauli Road, Anand Nagar Maharajganj (Name & Address of the School) on 12.04.2025 (date of inspection) and on the basis of Water Test Report (Attached) bearing No. UPJNMRJ/APRIL/25-26/11 Dated 16.04.2025 of District Level Water Analysis Laboratory (NABL Lab) Certificate that the Nav Jeevan Mission School (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/UT Govt.

The certificate is valid till 12.04.2025 to 12.10.2025


Executive Engineer
Division Office
U.P. Jal Nigam (Rural)
District-Maharajganj
उ० प्र० जल निगम (ग्रामीण)
महाराजगंज

To,

Nav Jeevan Mission School,
Sonauli Road, Anand Nagar
Maharajganj,

Note- The Certificate is to be issued by authorized officer / NABL Lab/Local bodies



**District Level Water Analysis Laboratory,
U.P. Jal Nigam(Rural), Maharajganj**
Rampur Satbhariya Water Supply Campus, Gorakhpur Road,
District-Maharajganj-273303



TC-12224

Lab ID: T-8716

Analysis Report

Rept. No. UPJNMRJ/APRIL/25-26/11

Date:- 16/04/2025

Page No. 1/2

Customer Name - Principal

Address - Nav Jeevan Mission School, Sonauli Road, Anand Nagar Maharajganj

Reference Letter No. -

Basic Details of sample

District- Maharajganj		Block- Pharenda	
Gram Panchayat/ Nagar	Anand Nagar	Village/Nagar	Anand Nagar
		Latitude	27.11286
		Longitude	83.281562
Habitation	Sonauli Road, Anand Nagar	Location	Nav Jeevan Mission School Campus
Water Source	H.P.	Date of S.C.	12.04.2025
Quantity of Sample	1500ml	Sample Collector	By Sampler
Receiving Date	12.04.2025	Analysis Completion Date-	16.04.2025
Sample Receive	Sushil Kumar		
Analysis Start Date	12.04.2025		
Temprature - 25 +-C		Relative Humidity - 50+-15%	

Technical Data of Analysis

S.No.	Analysed parameters (Unit of Measurement)	Observed Value	Unit	Specified Values as per BIS		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	Turbidity	1.84	NTU	1.00	5.00	IS 3025 (Part 10) : 2023
2	TDS	269.00	mg/L	500.00	2000.00	IS 3025 (Part 16) : 2023
3	pH	7.92	-	6.5 - 8.5	No relaxation	IS 3025 (Part 11) : 2022
4	Total Hardness	242.00	mg/L	200.00	600.00	IS 3025 (Part 21) : 2019
5	Total Alkalinity	268.00	mg/L	200.00	600.00	IS 3025 (Part 23) : 2023
6	Chloride as Cl	22.00	mg/L	250.00	1000.00	IS 3025 (Part 32) : 2019
7	Calcium	67.72	mg/L	75.00	200.00	IS 3025 (Part 40) : 2019
8	Magnesium	19.20	mg/L	30.00	100.00	IS 3025 (Part 46) : 2019
9	Colour	10.00	Hazen	5.00	15.00	IS 3025 (Part 4) : 2021

- Note:-**
1. This Certificate refers only to the particular sample(s) submitted for testing.
 2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
 3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
 4. Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of tests reports unless other wise specified.

[Signature]
Prepared By

[Signature]
Review By

[Signature]
(Radhe Mohan Pandey)
Quality Manager
Authorized Signatory
Mob No. 9838396541
Manager

Lab E-Mail ID :- ritikalanmrj@gmail.com

End of Test Report



District Level Water Analysis Laboratory,
U.P. Jal Nigam(Rural), Maharajganj
 Rampur Satbhariya Water Supply Campus, Gorakhpur Road,
 District-Maharajganj-273303

Rept. No. UPJNMRJ/APRIL/25-26/11

Date:- 16/04/2025

Page No. 1/2

Technical Data of Analysis

S.No.	Analysed parameters (Unit of Measurement)	Observed Value	Unit	Specified Values as per BIS		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	Conductivity	539.00	mS/cm	NA	NA	IS 3025 (Part 14)
2	Sulphate	69.02	mg/L	200.00	400.00	APHA24rd Edition-4500-SO4 Method E (Turbidimetric Method)
3	Nitrate	3.46	mg/L	45.00	No relaxation	APHA24rd Edition-4500-NO3 Method B (UV Screening Method)
4	Iron	0.124	mg/L	1.00	No relaxation	APHA24rd Edition-4500-FE Method B (Phenanthroline- Method)
5	Arsenic	0.00	mg/L	0.01	No relaxation	APHA24rd Edition-4500-As Method B (Silverdiethyldithiocarbamate- Method)
6	Fluoride	0.391	mg/L	1.00	1.50	APHA24rd Edition-4500-As Method C (Electrode - Method)
7	E-Coli (Bacteria)	0.00	CFU	NIII	NIII	IS 15181:2016

Note:-

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of tests reports unless other wise specified.

[Signature]
 Prepared By

[Signature]
 Review By

[Signature]
 (Radheyshyam Rawat)
 Quality Manager

Lab E-Mail ID :- ritikalalmrj@gmail.com

End of Test Report

